

Warehouse Fire Safety Checklist (US)

Safety & Compliance | US

DATE ____ / ____ / ____	INSPECTOR	FACILITY
----------------------------	-----------	----------

FIRE EXTINGUISHERS

	OK	NOT OK	N/A		OK	NOT OK	N/A
All extinguishers in designated locations <small>OSHA 1910.157 — max 75 ft travel distance</small>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Annual inspection tags current	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Gauges in green zone	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	No obstructions blocking access	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Safety pins and tamper seals intact	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Correct type for area (A, B, C, K)	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

SPRINKLER SYSTEM

	OK	NOT OK	N/A		OK	NOT OK	N/A
Sprinkler heads unobstructed	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Control valves open and locked	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
18 in. clearance below deflectors <small>NFPA 25</small>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Fire pump tested weekly	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
No damaged or painted heads	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Riser room accessible and dry	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

EMERGENCY EXITS & EVACUATION

	OK	NOT OK	N/A		OK	NOT OK	N/A
All exits clear and unobstructed <small>OSHA 1910.36/37</small>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Evacuation plans posted and current	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Exit signs illuminated	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Assembly point marked	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Emergency lighting functional	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Fire doors closing and latching	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

ALARM & DETECTION

	OK	NOT OK	N/A		OK	NOT OK	N/A
Fire alarm panel showing normal	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Manual pull stations accessible	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Smoke/heat detectors unobstructed	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Alarm tested per NFPA 72 schedule	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

ELECTRICAL SAFETY

	OK	NOT OK	N/A		OK	NOT OK	N/A
No overloaded circuits or daisy chains	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	No damaged wiring or exposed conductors	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Electrical panels 36 in. clearance <small>OSHA 1910.303(g)</small>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Forklift charging area ventilated	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

STORAGE PRACTICES

	OK	NOT OK	N/A		OK	NOT OK	N/A
Goods 18 in. below sprinkler deflectors	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Aerosol storage separated per NFPA 30B	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Aisles clear for emergency access	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Waste and recycling not accumulating	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Flammable liquids in approved cabinets <small>NFPA 30 / OSHA 1910.106</small>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	No combustibles near heat sources	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

Go digital with Miratag

 Skip the paper — fill checklists faster on the Miratag mobile app. Add photos, videos, notes and signatures. Track compliance in real time. Start free at miratag.com
This template is a general-purpose resource, not tailored to any specific jurisdiction. Each organisation must validate compliance with local regulations.


Scan to view

HOT WORK CONTROLS

	OK	NOT OK	N/A		OK	NOT OK	N/A
Hot work permits issued and current <i>OSHA 1910.252(a)</i>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Combustibles cleared 35 ft from work	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Fire watch assigned during hot work	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Welding screens in place	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

CORRECTIVE ACTIONS

Deficiencies found

Assigned to

Due date

Inspector signature

Notes

Go digital with Miratag

Skip the paper — fill checklists faster on the Miratag mobile app. Add photos, videos, notes and signatures. Track compliance in real time. Start free at miratag.com

This template is a general-purpose resource, not tailored to any specific jurisdiction. Each organisation must validate compliance with local regulations.



Scan to view